

**199—21.9(476) Incident reports.** A regulated public water utility shall notify the board when it notifies the Iowa department of natural resources or the local county health department about an incident involving: (1) an occurrence of waterborne emergency (e.g., treatment process malfunction, chemical/biological spill in the water supply, contamination event in the distribution system, emergency that has the potential for drinking water contamination); (2) a boil water advisory and contamination event; or (3) a low-pressure event (less than 20 psi) affecting a widespread area of the system. Notification shall be made to the board by calling the board duty officer at 515-745-2332. The caller shall leave a call-back number for a person knowledgeable about the incident. The utility shall report to the board when the incident has ended and normal water service has been restored.